

PROTEX

Central Heating System Additives



INHIBITED LEAKSEALANT FOR CENTRAL HEATING SYSTEMS

DIRECTIONS FOR USE

1. Protex leaksealant is recommended for use in sealing pin holes and small fractures.
It does not substitute any repair work which may be necessary.
2. Turn off boiler before use.
3. Add Protex Leaksealant to the system via the header tank. For best results drain a couple of litres of water from the system before adding the sealant. Top up with the water to ensure dispersion.
4. Circulate for 10 minutes for even distribution.
5. Use the self adhesive label to register date of application.

Leaksealant is a silicone based product, and its viscosity is affected by temperature. Placing this 1 litre bottle into a container of warm water and leaving to stand for 5-10 min's will aid flow of the product.



Protex Leak Sealant has been added to the water in this central heating system to provide leakage protection. To ensure continued protection, re-dose the system if the water is drained for any reason.

...../...../.....
Protex Leak Sealant is manufactured and supplied by:
Excel Industries, Coolmine Industrial Estate,
Clonsilla Road, Dublin 15, Ireland.
Tel: +353 (0) 1 8118701
Email: sales@excel-industries.com



Please use the self adhesive label to register date of application.